









# ELULED

# M E L B Y E






## Antipanikklys Selvtest



EI nummer	Type	Batteri	Lysstyrke
6685016	ELULED-1207-3H-ST	VRLA, 12V, 7Ah Valve Regulated Lead Acid	2 x 800 Lumen (800 Lumen/spot)

 I henhold til EN 60598-2-22 Standard	 Selvtest
 Opp til 22m dekning	 LED lyskilde, ingen behov for bytte av lyskilde
 Kapslingsgrad IP 65	 Egnet for tak montering
 3t batterireserve	 Egnet for vegg montering

### Avstand for rette fluktveier

Montasjehøyde (meter)					
2,00	4,09	9,66	9,66	9,66	4,09
2,50	5,11	12,08	12,08	12,08	5,11
3,00	5,70	13,58	13,58	13,58	5,70
3,50	6,11	14,70	14,70	14,70	6,11
4,00	6,47	15,69	15,69	15,69	6,47
4,50	6,78	16,57	16,57	16,57	6,78
5,00	7,05	17,36	17,36	17,36	7,05
6,00	7,49	18,74	18,74	18,74	7,49
7,00	7,79	19,87	19,87	19,87	7,79
8,00	7,97	20,78	20,78	20,78	7,97
9,00	8,01	21,56	21,56	21,56	8,01
10,00	7,93	22,07	22,07	22,07	7,93
11,00	7,70	22,46	22,46	22,46	7,70
12,00	7,38	22,65	22,65	22,65	7,38
13,00	6,89	22,66	22,66	22,66	6,89
14,00	6,19	22,48	22,48	22,48	6,19
15,00	5,07	22,10	22,10	22,10	5,07



#### WEEE Symbol for Batteries:

Separate collection for WEEE (Waste of electrical and electronic equipment)  
The battery should be sent to separate collection facilities for recovery and recycling.



#### WEEE Symbol:

Separate collection for WEEE (Waste of electrical and electronic equipment)  
The luminaire should be sent to separate collection facilities for recovery and recycling.

39/18

1

230 Volt, 50/60 Hz, max 5W,  
LED, 2 x 800 Lumen,  
LUMILEDS, 6500K, CRI>80  
12 VOLT, 7AH, VRLA,  
NON-MAINTAINED  
3H, IP 65, 0-25°C, CLASS II,  
RAL7035, 3.5Kg

2

4x

3

4x  
Ø6x35

195

140

4

4x

5

6a

6b

6c

7

8

230 V~  
50-60 Hz

8-9mm

0.75-2.5

9

BAT

10

MM-YY

11

48h

12

**LEGEND:**  
 ● off  
 ☀ on  
 ⚡ blink  
 ⚡ fast blink

**NORMAL**  
 TEST LED BAT OK OK

**AUTOMATISK SELV TEST**  
 TEST LED BAT OK TEST (funksjonstest 60s, årlig test 1t)

**BATTERI FEIL**  
 TEST LED BAT OK → (13) (14) (15) → RESET

**BATTERI AVKOBLET**  
 TEST LED BAT OK → →

**LAMPFEIL**  
 TEST LED BAT OK → → RESET

**MANUEL TEST**  
 TEST LED BAT OK → TEST LED BAT OK 60s funksjonstest  
 1s TEST

**FEIL RESET**  
 TEST LED BAT OK → TEST LED BAT OK Normal  
 1s RESET

→ 12 Volt, 7.0-7.2Ah, VRLA

13

→

14

→ BAT BAT

15

→ BAT BAT (48h)